

**LEGEND**


- ① 2" DOUBLE BRONZE SERVICE SADDLE – MUELLER BR2B "IP"
- ② 2" INSULATED CORPORATION STOP – MUELLER H-15023
- ③ 2" POLYETHYLENE PIPE. UNIONS OR COUPLINGS NOT PERMITTED
- ④ 2" COMPRESSION ADAPTER
- ⑤ 2" 90° BEND
- ⑥ 2" X SERVICE SIZE BUSHING
- ⑦ SERVICE SIZE BALL ANGLE METER VALVE – MUELLER B-24265
- ⑧ SERVICE SIZE WATER METER.
- ⑨ SERVICE SIZE NIPPLE, TYP.
- ⑩ SERVICE SIZE GATE VALVE – MILWAUKEE 105 – CUSTOMER FURNISHED & OWNED
- ⑪ PRESSURE REDUCING VALVE, TYPE WATTS 25-AUB-23 – CUSTOMER FURNISHED & OWNED
- ⑫ METER BOX  
PAVED AREAS – CHRISTY B30 BOX W/ CHRISTY B30D LID  
UNPAVED AREAS – CHRISTY FL30 BOX W/ CHRISTY FL30D LID
- ⑬ METER BOX SLAB – CHRISTY B30SL

**NOTES**

- 1. ALL FITTINGS SHALL BE BRASS
- 2. METER LOCATIONS TO BE DETERMINED BY DISTRICT.

**WATER SERVICE CONNECTION**

REV 10/06  
REV 4/05  
REV 1/05



**SKYLINE COUNTY WATER DISTRICT**  
SAN MATEO COUNTY, CALIFORNIA  
14944 Skyline Blvd., Woodside, CA 94062

Approved By:  
*Tamara Hannon*  
Tamara Hannon, General Manager

*Joubin Pakpour*  
Joubin Pakpour, District Engineer, RCE No. 59155

**STD NO.**  
**SK-01**